




## Technical Bulletin – Electrostatic Precipitators, Ozone Injection, Odour Neutraliser

Date: 13<sup>th</sup> June 2023

Electrostatic Precipitators, Ozone Injection, Odour Neutraliser System Maintenance Guidelines			
System	Filters	Maintenance	Approx. Replacement Costs
<p><b>Electrostatic Precipitator (Grease and Smoke)</b></p> 	<p>Grease Filter + ESP Cells</p>	<p><b>Ongoing Maintenance</b> Filters &amp; Cells Washable 3-6 Monthly</p> <p><b>Contracted Laundry Service</b> It is recommended that a service contract is considered for ESP cleaning due to fragile cells. <i>Approx Cost: £300-£400 per visit</i></p> <p><b>Replacements</b> Cells and Grease Filters typically need replacing after 2 years service to maintain efficiency. <i>Approx Cost: £40 Per Grease Filters £750 Per ESP Cell</i></p>	<p>£££</p>
<p><b>Ozone Injector Odour Control System</b></p> 	<p>N/A</p>	<p><b>Ongoing Costs</b> 6 monthly Inspection <i>Approx Cost: £300-£400 per visit</i></p> <p><b>Replacements</b> 2 Year ozone injector replacement <i>Approx Cost: 75% purchase price</i></p>	<p>££</p>
<p><b>Odour Neutraliser</b></p> 	<p>N/A</p>	<p><b>Ongoing Maintenance</b> Daily checking of the Odour Eliminating Chemicals level and topping it up if necessary.</p> <p><i>Note: An average installation should use approximately one litre of Odour Eliminating Chemical solution every three to four weeks.</i></p>	<p>£</p>

**Please Note: Maintenance requirements for all systems can vary depending on the style of cooking and number of covers.**